



Montana Department of  
**ENVIRONMENTAL QUALITY**

Brian Schweitzer, Governor

P. O. Box 200901

Helena, MT 59620-0901

(406) 444-2544

Website: [www.deq.mt.gov](http://www.deq.mt.gov)

**PUBLIC NOTICE NO. MT-12-01**

**January 9, 2012**

PURPOSE OF PUBLIC NOTICE

The purpose of this notice is to state the Department's intention to issue a wastewater discharge permit to the facility listed in this notice. This permit is issued by the Department under the authority of 75-5-402, Montana Code Annotated (MCA); the Administrative Rules of Montana (ARM) 17.30.1301 *et seq.*, Montana Pollutant Discharge Elimination System (MPDES); and Sections 402 and 303 of the Federal Clean Water Act. The Water Protection Bureau has prepared a draft permit for the facility listed below. Copies of the draft permit, fact sheet, and environmental assessment are available upon request from the Water Protection Bureau or on the Department's website [www.deq.mt.gov](http://www.deq.mt.gov).

APPLICANT INFORMATION

APPLICANT: City of Livingston

FACILITY NAME: City of Livingston Wastewater Treatment Plant

FACILITY LOCATION: 316 Bennett Street, Park County

RECEIVING WATER: Yellowstone River

PERMIT NUMBER: MT0020435

The city is working with the Department to meet *Escherichia coli* (*E. coli*) effluent limits in the permit under an Administrative Order on Consent (AOC) Docket No. WQ-10-07. To meet *E. coli* effluent limits, the existing ultraviolet (UV) disinfection system requires supplemental chlorine addition. Supplemental chlorine addition is required because rotating biological contactor units sloughs off large clumps of bacterial particles that interfere with the UV disinfection system. As a result, the facility cannot meet the *E. coli* effluent limits in the permit. To meet *E. coli* effluent limits, the city will install chlorination and dechlorination systems.

On September 21, 2000, a U.S. District Judge issued an order stating that until all necessary total maximum daily loads (TMDLs) under Section 303(d) of the Clean Water Act are established for a particular water quality limited segment, the State is not to issue any new permits or increase permitted discharges under the MPDES program. The order was issued in

Public Notice No.: MT-12-01

January 9, 2012

Page 2 of 2

the lawsuit Friends of the Wild Swan v. U.S. EPA, et al., CV 97-35-M-DWM, District of Montana, Missoula Division. The DEQ finds that the issuance of this proposed permit does not conflict with the order because it is not a new permit and the renewed permit will reduce the pollutant load to the Yellowstone River.

#### PUBLIC COMMENT

Public comments are invited ANYTIME PRIOR TO CLOSE OF BUSINESS February 8, 2012. Comments may be directed to the DEQ Permitting & Compliance Division, Water Protection Bureau, PO Box 200901, Helena, MT 59620. All comments received or postmarked PRIOR TO CLOSE OF BUSINESS February 8, 2012 will be considered in the formulation of final determinations to be imposed on the permits. If you wish to comment electronically, you may e-mail Noelle Uncles or Barb Sharpe at [WPBPublicNotices@mt.gov](mailto:WPBPublicNotices@mt.gov).

During the public comment period provided by the notice, the Department will accept requests for a public hearing. A request for a public hearing must be in writing and must state the nature of the issue proposed to be raised in the hearing (ARM 17.30.1373).

The Department will respond to all substantive comments and issue a final decision within sixty days of this notice or as soon as possible thereafter. Additional information may be obtained upon request by calling (406) 444-3080 or by writing to the aforementioned address. The complete administrative record, including permit application and other pertinent information, is maintained at the Water Protection Bureau office in Helena and is available for review during business hours.

**PUBLIC NOTICE NO. MT-12-01**  
**January 12, 2012**